

## Government Of West Bengal Office Of The Director General West Bengal Fire & Emergency Services 13D, Mirza Ghalib Street, Kolkata - 16

Memo

no.:WBFES/5253/14/Kol/EB/976/14(976/14)

From:

Director

Fire Prevention Wing,

West Bengal Fire & Emergency Services

To: SHREE SHWETAMBAR STHANAKVASI JAIN SABHA.
PLOT NO-IIA/14, STREET NO-374, UNDER NEW TOWN P.S,KOLKATA,PIN-700156

Sub: Revised Fire Safety Recommendation for addition & alteration of existing G+VI storied under group of Educational Building at PLOT NO-IIA/14, STREET NO-374, UNDER NEW TOWN P.S, KOLKATA, PIN-700156.

This is in reference to your application no. 0125188221100105 dated 20-08-2022 regarding the Revised Fire Safety Recommendation for addition & alteration of existing G+VI storied under group of Educational Building at PLOT NO-IIA/14, STREET NO-374, UNDER NEW TOWN P.S, KOLKATA, PIN-700156.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this office is issuing **Revised Fire Safety Recommendation** in favor of the aforesaid building subject to the compliance of the following fire safety measure.

## Recommendation:

The revised plan drawing submitted by you were scrutinized and marked as found necessary from fire safety point of view. In returning one set of plan with recommendation, this office is issuing further Revised Fire Safety Recommendation in favour of the aforesaid building subject to the compliance of the earlier Fire Safety Recommendation was issued vide this office memo no. WBFES/5253/14/Kol/EB/976/14(976/14) dt. 11.11.2014 will remain same and strictly to be followed.

## In addition :

## 1. Sprinkler Installation:

The automatic sprinkler installation shall be provided in all Floor areas and alarm gang to be incorporated along with the sprinkler system. Sprinkler test line shall have to be provided as per suitability. Separate sprinkler pump shall have to be provided of 2850 LPM capacity with appropriate head.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number: 0125188221100105.

Validity unknown
Digitally signed by BHIJIT
PANDEY
Date: 2022.1 1 B44:15:02 IST

Jency Service

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number: 0125188221100105.

Page: 2